

Locations	1st Test 10/05/17 (parts per billion)			Improvements 10/30 to 11/08/17	2ND Test 11/09/17 (ppb)			3RD Test 01/24/18 (ppb)			Remarks
	1ST Draw	2ND Draw	<5ppb		1ST Draw	2ND Draw	<5ppb	1ST Draw	2ND Draw	<5ppb	
School Kitchen #1	51.5	6.5	No/No	Replaced faucet/flexible hose and fitting	1870	339	No/No	12.5	1.7	No/Yes	Replaced existing piping. OK, will flush for 2min. before using.
#2	8.5	1.1	No/Yes	Replaced faucet aerator	16.1	11.0	No/No	1.0	1.0	Yes/Yes	OK, replaced piping
#3	5.5	1.0	No/Yes	Replaced faucet aerator	2.3	1.0	Yes/Yes	1.0	1.0	Yes/Yes	OK, replaced piping
#4	300	2.2	No/Yes	Replaced total faucet	9.8	95	No/No	-	-	No/No Test	OK, test not required. Only used to wash hands
#5	10.8	1.0	No/Yes	Replaced faucet/flexible hose and stop valve	15.5	1.2	No/Yes	10.2	1.0	No/Yes	OK, only used to fill steam pans. Not for drinking or cooking
Teachers Lounge	5.7	1.3	No/Yes	Replaced faucet aerator	4.8	1.0	Yes/Yes	-	-	No/No Test	OK
Gym Kitchen #1	14.6	1.9	No/Yes	Replaced faucet/flexible hose with standard faucet	11.2	1.2	No/Yes	-	-	No/No Test	OK, will flush for 2min. before using
#2	2.2	1.0	Yes/Yes	None	-	-	/	-	-	No/No Test	OK
#3	7.7	1.5	No/Yes	Replaced faucet aerator	5.7	1.0	No/Yes	-	-	No/No Test	OK, will flush for 2min. before using
Drinking Fountain #1	1.0	1.0	Yes/Yes	None	-	-	/	-	-	No/No Test	OK
#2	1.0	1.0	Yes/Yes	None	-	-	/	-	-	No/No Test	OK
#3	1.0	1.0	Yes/Yes	None	-	-	/	-	-	No/No Test	OK
#4	1.0	1.0	Yes/Yes	None	-	-	/	-	-	No/No Test	OK
#5	2.0	1.6	Yes/Yes	None	-	-	/	-	-	No/No Test	OK